



广微测
Gmicro Testing



201819000883



中国认可
国际互认
检测
TESTING
CNAS L1747

广东省微生物分析检测中心

GUANGDONG DETECTION CENTER OF MICROBIOLOGY

分析检测报告

REPORT FOR ANALYSIS

报告编号

2020FM22484R01D

Report №.

样品名称

空调-隐藏式家用空调紫外线 LED 灯

Name of Sample

UV Air Sterilizing LED for Mini Split

委托单位

深圳飞腾国际贸易管理有限公司

Applicant

Shenzhen Feiteng International Trade Management Co.,Ltd

检测类型

Test Type

委托检测
Entrustment Test

单位地址: 广州市先烈中路 100 号大院 66 号楼

Address: Building 66, No.100 Central Xian Lie Road, Guangzhou, China

邮政编码: 510070

Postcode:

电话号码: (020)87137666

Tel:

传真号码: (020)87137668

Fax:

网 址: www.gddcm.com

Website:



广微测
Gmicro Testing



201819000883



中国认可
国际互认
检测
TESTING
CNAS L1747

广东省微生物分析检测中心

GUANGDONG DETECTION CENTER OF MICROBIOLOGY

分析检测报告

REPORT FOR ANALYSIS



报告编号 (Report No.) 2020FM22484R01D 校验码 (Verification Code): 38694275

样品名称 Name of Sample	空调-隐藏式家用空调紫外线 LED 灯 UV Air Sterilizing LED for Mini Split	检测类型 Test Type	委托检测 Entrustment Test
委托单位 Applicant	深圳飞腾国际贸易管理有限公司 Shenzhen Feiteng International Trade Management Co.,Ltd	地 址 Address	深圳市福田区福田街道岗厦社区 福华三路 88 号财富大厦 2 层 8002 8002,2f,Fortune Building,No.88,Fuhua Third Road, Gangxia community, Futian street, Futian District, Shenzhen
样品来源 Sample Source	委托方送检 Submitted for Testing by the Applicant	样品数量 Sample Quantity	1 个 One Sample Submitted
样品规格和批号 Spec and Lot No of Sample	ACLS50D	样品状态和特性 State and Characteristic	机器 Machine
接样日期 Sample Received Date	2020-07-31	检测完成日期 Completion Date	2020-08-24
检测依据和方法 Test Standard and Method	《消毒技术规范》2002 年版-2.1.3 Technical Standard for Disinfection (2002 Ministry of Health P.R.China)-2.1.3		
检测项目 Item Tested	空气消毒效果实验室试验 Air disinfection effect: laboratory test		
检测结论 Test Conclusion	该样品所检项目的实测数据见本检测报告续页。 The test data of the sample(s) is attached to the page(s) of this report. 签发日期: 2020-09-01 Issue Date: 机构盖章 Official Seal 检验检测专用章		
备注 Remarks			

制表:
Editor

印婉仪

审核:
Verifier

苗晖

批准:
Approver

张保



广东省微生物分析检测中心

GUANGDONG DETECTION CENTER OF MICROBIOLOGY

分 析 检 测 结 果

ANALYSIS AND TEST RESULT

报告编号 (Report No.): 2020FM22484R01D

作用时间 Action time	测试微生物 The test microorganism	序号 Serial Number	空气中细菌总数 The number of Bacteria in the air (cfu/m³)	杀灭率 Killing rate (%)
0（CK）	白色葡萄球菌 (<i>Staphylococcus albus</i>) 8032	1	3.8×10 ⁶	/
		2	3.8×10 ⁶	/
		3	3.9×10 ⁶	/
30min	白色葡萄球菌 (<i>Staphylococcus albus</i>) 8032	1	5.4×10 ⁵	81.05
		2	4.6×10 ⁵	84.67
		3	5.5×10 ⁵	81.80
2h	白色葡萄球菌 (<i>Staphylococcus albus</i>) 8032	1	7.3×10 ³	99.55
		2	5.5×10 ³	99.64
		3	8.2×10 ³	99.53
(以下空白 Blank Below)				
备注 Remarks	1.方法简述:在空间为 1m³ 的试验柜内,即在实验室试验的条件下,开启送检样品风扇模式并调整风量到最低,分别作用 30min 和 2h 后,用液体撞击式微生物气溶胶采样器以 11L/min 的流量进行采样,采样液的体积为 20mL。试验组与对照组的采样时间均为 2min。 Method description: Put the test sample in a 1m³ test cabin,and then carried out the following steps under laboratory conditions: Turned the test sample on fan mode and adjusted the air volume to the minimum effect for 30min and 2h, respectively,then collected the air at a flow of 11L/min by a pump liquidaerosol sampler to test the content of airbacteria.The volume of sampling solution was 20mL,the sampling time was 2min both in control group and test gronp. 2.杀灭率试验结果已消除微生物在空气中自然消亡因素的影响。 The result of killing rate has eliminated the natural decay of microorganisms in the air.			



报告编号 (Report №.): 2020FM22484R01D

注意事项 Notice Items

1. 检测报告无本单位检验检测专用章、骑缝章无效。

The Test report is invalid if not affixed with Authorized Stamp of Test and Paging Seal.

2. 检测报告无审核人、批准人签字无效。

The Test report is invalid without signature of verifier and approver.

3. 检测报告涂改增删无效。

The Test report is invalid if being supplemented, deleted or altered.

4. 未经本单位书面同意，不得部分复制（全部复制除外）本检测报告。

Without prior written permission, the report cannot be reproduced, except in full.

5. 除非另有说明，本报告检验结果仅对来样负责。

Unless otherwise stated, the results shown in this test report refer only to the sample(s) submitted.

6. 对检测报告有异议的，应于收到报告之日起十五日内提出，逾期不予受理。

Any dispute of the report must be raised to the testing body within 15 days after the report is received, exceeding which the dispute will not be accepted.

7. 对送检样品，样品信息由委托方提供，本单位不对其真实性负责。

For the tested sample(s) submitted by the applicant, the sample information in the test report is provided by the applicant and the laboratory is not responsible for its authenticity.

检测专用章